



# **SECTION** NTS

IPS = IRON PIPE SIZE  
FIP = FEMALE IRON PIPE THREAD  
MIP = MALE IRON PIPE THREAD

## NOTES:

1. CORPORATION STOP SERVICE CONNECTIONS SHALL BE USED FOR ALL SERVICE LINES 2 INCH AND SMALLER.
2. ATTACH 12 GAUGE TRACER WIRE (BLUE) TO WATER MAIN TO MAKE ELECTRICALLY CONTINUOUS.
3. SERVICE PIPE SHALL BE BURIED IN CRUSHED SURFACING TOP COURSE.
4. DIRECT TAPPING OF WATER MAIN IS NOT ALLOWED.

*Scott Thomasson*

APPROVED BY: SCOTT THOMASSON  
WATER/WASTEWATER ENGINEERING MANAGER

REVISION DATE: MARCH 01, 2017



City of Redmond  
WASHINGTON

STANDARD DETAILS

**CORPORATION STOP  
SERVICE CONNECTION**

FILE NAME: SD701A.DWG DETAIL NUMBER: 701A